

Proceedings of the Tahsildar, Vilavancode@ Kuzhithurai

Present: Thiru. T. Julian Hewar, B.Sc.,

K. Dis.B2/ 3035/2024

Dated: 18.09.2024

Sub : Building License – Vilavancode Taluk, Mancode Village, **Bright International School, Kadavankonam, Vellachiparai Post Kanniyakumari District** renewal of Building License granted – Regarding.

Ref : Connected records.

Order:

Building License is renewed in favour of the Correspondent, **Bright International School, Kadavankonam, Vellachiparai Post**, for his buildings bearing Door No.II-2-133C & II-2-133/5. The building is situated at Re.Sy.Nos. 199/5A, 5B1, 5B2, 5B3, 5B4, 5B5, 5C1, 5C2, 5D1 & 5E2 of Mancode Village.

The license is renewed under section 2(i) of section 7 of the Tamil Nadu Building license Act1965, Subject to the following conditions.

1. The School building authorities should not construct any roofs with materials which are easily inflammable and pose threat of fire menace after receipt of building license.
2. They should maintain electrical connections properly and it should be fire free.
3. They should pave way to impart trainings to their staff and enable them to do firefighting demonstrations in the event of contingencies.
4. They are solely responsible for any lapse on above lines if any fire mishap takes place in future.

The license in form D is enclosed herewith

Encl : Form D

To

**The Correspondent,
Bright International School,
Kadavankonam,
Vellachiparai Post.**



Tahsildar,
Vilavancode.

18/9/2024

18/9/24

Bilri

Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152

FORM -D

Form of License under section (1) section 6 of the Madras Public Building (Licensing) ACT 1965 (Madras Act 19 of 1965) referred to the rule of the Madras Public Building Licensing Rules 1965.

Registration No.K. Dis.B2/3035/2024


License No : 47/2024

Fee Rs : 1000/-

License is hereby renewed to the Correspondent,**Bright International School, Kadavankonam, Vellachiparai Post.**

The Period of validity of the License : 01.08.2024 to 31.07.2027

License shall be for the Door No. : **II-2-133C & II-2-133/5.**
Re.Sy.No. 199/5A, 5B1, 5B2, 5B3, 5B4, 5B5, 5C1, 5C2, 5D1 & 5E2



Tahsildar,
Vilavancode. *18/9/2024*

STATEMENT TO ACCOMPANY THE LICENCE

Location of the building (Door No. Street No. and Name of place)	Purpose for which the building is license to be used as a public buildings	No. of Persons to be Accommodated
Door No: II-2-133C & II-2-133/5. Re.Sy.No. 199/5A, 5B1, 5B2, 5B3, 5B4, 5B5, 5C1, 5C2, 5D1 & 5E2 Bright International School, Kadavankonam, Vellachiparai Post.	Educational	140 Nos. 200 Nos

Note: The application for renewal of the license should be sent one month before the expiry date.




Tahsildar,
Vilavancode. *18/9/2024*

Balsi
Principal
Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152



JOE ASSOCIATES

CONSULTING ARCHITECTS, ENGINEERS & VALUERS
BERACHAH TOWER, CHIRAYANKUZHI JN., KANJIRACODE P.O., PIN : 629 155.

Mob : 9443607580, Email : pisonjoe@yahoo.com, pisonjoe@gmail.com



Er. J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng (I), F.I.V.

Website: www.joeassociates.com

Regd. Engineer Grade - I | Regd. Structural Eng. Grade - II | S. B. I. Valuer | Approved Valuer | Bank of India Valuer | Indian Bank Valuer | Govt. Regd. Valuer | Karnataka Bank Valuer
Dist. Panel Eng. Class-IA | Govt. Registered Engineer | P.N.B. Valuer | Chartered Engineer | Federal Bank Valuer | TIIIC Panel Valuer | I. O. B. Panel Valuer | Bank of Maharashtra Valuer

STATEMENT ACCOMPANYING FORM - A

B2/S/24

1. Door Number of Building : II - 2 - 133 C
2. Location (street no., ward no.) Name of place i.e. Corp./ Municipality / Panchayat Union / Township : **Bright International School,**
Kadayamkonam, Vellachiparai P. O.
R. S. No: 199 / 5C2.
3. Year of construction : 2017 & 2019
4. Approx. cost of construction as per current rates : ₹ 35,00,000/-
5. Purpose for which the building is being used or proposed to be used : Class Rooms & Office.
6. Purpose for which the building has hither to been used : Class Rooms & Office.
7. Details of construction of the building (particulars of the foundation soil, specification of the various parts under):
 - i. Foundation : R.R.M. in Cement Mortar.
 - ii. Basement : R.R.M. in Cement Mortar
 - iii. Superstructure : B.W. in Cement Mortar
 - iv. Floor : Marbonite Flooring
 - v. Roof : R.C.C.
8. Period for which license is required : **01.08.2024 to 31.07.2027 (Three Years)**
9. Number of persons to be accommodated : **140 Nos.**

Date : 19.08.2024


Govt. Registered Engineer

Er. J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng (I), F.I.V.
Dist. Panel Engineer, Class - IA
JOE ASSOCIATES
CHIRAYANKUZHI, MARTHANDAM, Mob: 9443607580

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition or alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Date:



Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152


Signature of the owner of the building

FORM – B

Form of certificate of Structural Soundness under sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule of the Madras Public Building (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

- i. Depth below Ground Level : 1.80 m
- ii. Nature of soil met with at foundation level : Hard Gravelly soil
- iii. Pressure of foundation : 26.80 t/m²
- iv. Probable S.B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

- i. Maximum stress in the most critical section of masonry and Concrete : Does not arise since it is a Framed Structure
- ii. Nature of masonry and Concrete and its safe permissible stress : ----

The structural soundness of the building has been verified by me with reference to ISI loading standard 875 (Latest version) and other relevant INDIAN STANDARDS CODE OF PRACTICE and I declare the building is structurally sound to be used as Public Building for the purpose noted in the statement. A license may be granted for the period from **01.08.2024 to 31.07.2027** (Three Years)

Date : 19.08.2024



Govt. Registered Engineer

Er.J.PISON JOE, B.Sc.,B.E.,M.I.E.,C.Eng.(I),F.I.V.
Dist. Panel Engineer, Class - IA
JOE ASSOCIATES
CHIRAYANKUZHI, MARTHANDAM, Mob: 9443607580

Bibi

Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152

FORM – C

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door no., Street and Place.	Age of the building	No. of stories	Short description	Certified purpose the building stability	Certified period for the building stability	No. of persons to be accommodated	Remarks
2 / 133 / 5 Bright International School Kadayamkonam, Vellachiparai P.O. R. S. No: 199 / 5C	New	G.F., F.F, & T.F. Three stories	R.C.C. Framed Structure, Country wood Doors & Windows	Class Rooms	01.08.2024 to 31.07.2027 (Three years)	200 Nos.	G.F. Completed, F.F. & S.F. Under Construction



Date : 19.08.2024

Govt. Registered Engineer

Er.J.PISON JOE, B.Sc.,B.E.,M.I.E.,C.Eng.(I),F.I.V.
Dist. Panel Engineer, Class - IA
JOE ASSOCIATES
CHIRAYANKUZHI, MARTHANDAM, Mob: 9443607580

Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152

STATEMENT ACCOMPANYING FORM - A

B3/S/25

1. Door Number of Building : **2 / 133 / 5**
2. Location (street no., ward no.) Name of place i.e. Corp./ Municipality / Panchayat Union / Township : **Bright International School,**
Kadavankonam, Vellachiparai P. O.
R. S. Nos: 199/5A, 5B1,5B2,5B3,5B4,5B5
5C1, 5C2, 5D1 & 5E2, Mancode Village.
3. Year of construction : **G.F.: 2024 & F.F. & S.F: 2025**
4. Approx. cost of construction as per current rates : **₹ 1,55,00,000/-**
5. Purpose for which the building is being used or proposed to be used : **Class Rooms**
6. Purpose for which the building has hither to been used : **Class Rooms**
7. Details of construction of the building (particulars of the foundation soil, specification of the various parts under):
 - i. Foundation : **R.C.C. Column footing**
 - ii. Basement : **R.R.M. in Cement Mortar**
 - iii. Superstructure : **R.C.C. Framed Structure & C.B. in C.M.**
 - iv. Floor : **Vitrified Tiles**
 - v. Roof : **R.C.C.**
8. Period for which license is required : **01.08.2025 to 31.07.2027 (Two Years)**
9. Number of persons to be accommodated : **600 Nos.**

Date : 09.09.2025

Govt. Registered Engineer

Er.J.PISON JOE, B.Sc.,B.E.,M.I.E.,C.Eng.(I),F.I.V.

Dist. Panel Engineer, Class - IA

JOE ASSOCIATES

CHIRAYANKUZZHI, MARTHANDAM, Mob: 9443607580

Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh license, in case addition or alteration is made to the existing building or portion of the building. I also undertake to obtain fresh license if the purpose for which the license was granted for the use of the building originally is changed or altered subsequently.

Bibi

Principal

Date:

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152

A.veen
Signature of the owner of the building

FORM - B

Form of certificate of Structural Soundness under sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule of the Madras Public Building (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features:

1. FOUNDATION

- i. Depth below Ground Level : 1.80 m
- ii. Nature of soil met with at foundation level : Hard Gravelly soil
- iii. Pressure of foundation : 30.26 t/m²
- iv. Probable S.B Capacity of the strata met with at foundation : 45 t/m²

2. SUPERSTRUCTURE

- i. Maximum stress in the most critical section of masonry and Concrete : Does not arise since it is a Framed Structure
- ii. Nature of masonry and Concrete and its safe permissible stress : ---

The structural soundness of the building has been verified by me with reference to ISI loading standard 875 (Latest version) and other relevant INDIAN STANDARDS CODE OF PRACTICE and I declare the building is structurally sound to be used as Public Building for the purpose noted in the statement. A license may be granted for the period from **01.08.2025 to 31.07.2027** (Two Years)



Date : 09.09.2025

Govt. Registered Engineer

Er. J. PISON JOE. B.Sc., B.E., M.I.E., C.Eng. (I), F.I.V.
Dist. Panel Engineer, Class - IA
JOE ASSOCIATES
CHIRAYANKUZH, MARTHANDAM, Mob: 9443607580

Bibi

Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152

FORM - C

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door no., Street and Place.	Age of the building	No. of stories	Short description	Certified purpose the building stability	Certified period for the building stability	No. of persons to be accommodated	Remarks
2 / 133 / 5 Bright International School Kadavankonam, Vellachiparai P.O. R. S. Nos: 199/5A, 5B1,5B2,5B3,5B4, 5B5, 5C1, 5C2, 5D1 & 5E2, Mancode Village.	G.F.: One Year & F.F., S.F.: New	G.F., F.F, & T.F. Three stories	R.C.C. Framed Structure, Country wood Doors & Windows	Class Rooms	01.08.2025 to 31.07.2027 (Two years)	600 Nos.	---



Date : 09.09.2025

Govt. Registered Engineer

Er. J. PISON JOE, B.Sc., B.E., M.I.E., C.Eng. (I), F.I.V.
Dist. Panel Engineer, Class - IA
JOE ASSOCIATES
CHIRAYANKUZHI, MARTHANDAM, Mob: 9443607580

Bibi

Principal

Bright International school
Kadavankonam, Panachamoodu
K.K. District - 629 152